

# WATER WELL REPORT

STATE OF WASHINGTON

Application No.

Permit No. G1-24612

(1) OWNER: Name BILL GORE Address 658 CLUTE ROAD CLALLAM

(2) LOCATION OF WELL: County ISLAND NE 1/4 NE 1/4 Sec 34 T29 N. R7E W.M.

Bearing and distance from section or subdivision corner 2000' NB. A sec 34 700' E (650' W 350' S OF NE COR. SEC. 34)

(3) PROPOSED USE: Domestic ☐ Industrial ☐ Municipal ☒  
Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) \_\_\_\_\_  
New well ☐ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 85 ft. Depth of completed well 85 ft.

(6) CONSTRUCTION DETAILS:  
Casing installed: 6 " Diam. from 0 ft. to 75 ft.  
Threaded ☐ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Welded ☒ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☐  
Type of perforator used \_\_\_\_\_  
SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☒ No ☐ JOHNSTON  
Manufacturer's Name S. B. WELCO  
Type 6 Model No. \_\_\_\_\_  
Diam. 6 Slot size 6 from 75 ft. to 85 ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☐ Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft.  
Material used in seal Benolite  
Did any strata contain unusable water? Yes ☐ No ☐  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation 350 ft.  
Static level 60 ft. below top of well Date \_\_\_\_\_  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made? Yes ☐ No ☐ If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)  
Time Water Level Time Water Level Time Water Level  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
Date of test \_\_\_\_\_  
Baller test 10 gal./min. with 25 ft. drawdown after 4 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	1
SAND BR	1	30
SAND + CLAY BR	30	60
SAND WW BR	60	85

RECEIVED  
APR 29 1987  
DEPARTMENT OF ECOLOGY  
NORTHWEST REGION

Work started 12/16, 1986. Completed 12/16/86, 1986

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B. W. DRILLING  
(Person, firm, or corporation) (Type or print)

Address 4087 E DOLIK RD CLALLAM

[Signed] [Signature]  
(Well Driller)

License No. 264 Date 12/15, 1986